



MALAYSIAN STANDARD

MS IEC 62305-1:2007

PROTECTION AGAINST LIGHTNING-PART 1: GENERAL PRINCIPLES (FIRST REVISION) (IEC 62305-1:2006, IDT)

ICS: 91.120.40, 29.020

Descriptors: lightning protection, installations and contents

© Copyright 2007

DEPARTMENT OF STANDARDS MALAYSIA

DEVELOPMENT OF MALAYSIAN STANDARDS

The **Department of Standards Malaysia (STANDARDS MALAYSIA)** is the national standardisation and accreditation body.

The main function of the Department is to foster and promote standards, standardisation and accreditation as a means of advancing the national economy, promoting industrial efficiency and development, benefiting the health and safety of the public, protecting the consumers, facilitating domestic and international trade and furthering international cooperation in relation to standards and standardisation.

Malaysian Standards are developed through consensus by committees which comprise of balanced representation of producers, users, consumers and others with relevant interests, as may be appropriate to the subject in hand. To the greatest extent possible, Malaysian Standards are aligned to or are adoption of international standards. Approval of a standard as a Malaysian Standard is governed by the Standards of Malaysia Act 1996 (Act 549). Malaysian Standards are reviewed periodically. The use of Malaysian Standards is voluntary except in so far as they are made mandatory by regulatory authorities by means of regulations, local by-laws or any other similar ways.

The Department of Standards appoints **SIRIM Berhad** as the agent to develop Malaysian Standards. The Department also appoints SIRIM Berhad as the agent for distribution and sale of Malaysian Standards.

For further information on Malaysian Standards, please contact:

Department of Standards Malaysia

Level 1 & 2, Block C4, Parcel C

Federal Government Administrative Centre
62502 Putrajaya
MALAYSIA

Tel: 60 3 88858000

Fax: 60 3 88885060

<http://www.standardsmalaysia.gov.my>

E-mail: central@standardsmalaysia.gov.my

OR **SIRIM Berhad**

(Company No. 367474 - V)

1, Persiaran Dato' Menteri
P.O. Box 7035, Section 2
40911 Shah Alam
Selangor D.E.

Tel: 60 3 5544 6000

Fax: 60 3 5510 8095

<http://www.sirim.my>

CONTENTS

COMMITTEE REPRESENTATION.....	iv
NATIONAL FOREWORD	v
FOREWORD.....	vi
INTRODUCTION.....	viii
1 Scope.....	15
2 Normative references.....	15
3 Terms and definitions	15
4 Lightning current parameters	27
5 Damage due to lightning	27
5.1 Damage to a structure	27
5.2 Damage to a service.....	33
5.3 Types of loss	35
6 Need and economic convenience for lightning protection.....	39
6.1 Need for lightning protection	39
6.2 Economic convenience of lightning protection	41
7 Protection measures.....	41
7.1 Protection measures to reduce injury of living beings due to touch and step voltages.....	41
7.2 Protection measures to reduce physical damage.....	41
7.3 Protection measures to reduce failure of electrical and electronic systems	43
7.4 Protection measures selection	43
8 Basic criteria for protection of structures and services.....	43
8.1 Lightning protection levels (LPL)	45
8.2 Lightning protection zones (LPZ).....	53
8.3 Protection of structures.....	55
8.4 Protection of services	57
Annex A (informative) Parameters of lightning current	59
Annex B (informative) Time functions of the lightning current for analysis purposes	75
Annex C (informative) Simulation of the lightning current for test purposes	87
Annex D (informative) Test parameters simulating the effects of lightning on LPS components	95
Annex E (informative) Surges due to lightning at different installation points	125
Bibliography.....	135

Figure 1 – Types of loss and corresponding risks resulting from different types of damage.....	39
Figure 2 – LPZ defined by an LPS (IEC 62305-3).....	49
Figure 3 – LPZ defined by protection measures against LEMP (IEC 62305-4)	51
Figure A.1 – Definitions of short stroke parameters (typically $T_2 < 2$ ms).....	59
Figure A.2 – Definitions of long stroke parameters (typically $2 \text{ ms} < T_{\text{long}} < 1 \text{ s}$).....	61
Figure A.3 – Possible components of downward flashes (typical in flat territory and to lower structures)	61
Figure A.4 – Possible components of upward flashes (typical to exposed and/or higher structures)	63
Figure A.5 – Cumulative frequency distribution of lightning current parameters (lines through 95 % and 5 % value).....	69
Figure B.1 – Waveshape of the current rise of the first short stroke	77
Figure B.2 – Waveshape of the current tail of the first short stroke	79
Figure B.3 – Waveshape of the current rise of the subsequent short strokes.....	81
Figure B.4 – Waveshape of the current tail of the subsequent short strokes.....	83
Figure B.5 – Amplitude density of the lightning current according to LPL I.....	85
Figure C.1 – Example test generator for the simulation of the specific energy of the first short stroke and the charge of the long stroke	89
Figure C.2 – Definition for the current steepness in accordance with Table C.3.....	91
Figure C.3 – Example test generator for the simulation of the front steepness of the first short stroke for large test items	93
Figure C.4 – Example test generator for the simulation of the front steepness of the subsequent short strokes for large test items.....	93
Figure D.1 – General arrangement of two conductors for the calculation of electrodynamic force	109
Figure D.2 – Typical conductor arrangement in an LPS.....	109
Figure D.3 – Diagram of the stresses for the configuration of Figure D.2.....	111
Figure D.4 – Force per unit length along the horizontal conductor of Figure D.2	111
Table 1 – Effects of lightning on typical structures	29
Table 2 – Effects of lightning on typical services	33
Table 3 – Damages and loss in a structure according to different points of strike of lightning	37
Table 4 – Damages and loss in a service according to different points of strike of lightning	37
Table 5 – Maximum values of lightning parameters according to LPL.....	47
Table 6 – Minimum values of lightning parameters and related rolling sphere radius corresponding to LPL	53
Table 7 – Probabilities for the limits of the lightning current parameters	53
Table A.1 – Tabulated values of lightning current parameters taken from CIGRE (Electra No. 41 or No. 69*) [3], [4]	65
Table A.2 – Logarithmic normal distribution of lightning current parameters – Mean μ and dispersion σ_{\log} calculated from 95 % and 5 % values from CIGRE (Electra No. 41 or No. 69) [3], [4].....	67

Table B.1 – Parameters for Equation B.1	75
Table C.1 – Test parameters of the first short stroke	89
Table C.2 – Test parameters of the long stroke	89
Table C.3 – Test parameters of the short strokes	91
Table D.1 – Summary of the lightning threat parameters to be considered in the calculation of the test values for the different LPS components and for the different LPL.....	97
Table D.2 – Physical characteristics of typical materials used in LPS components	103
Table D.3 – Temperature rise for conductors of different sections as a function of W/R	103
Table E.1 – Conventional earthing impedance values Z and Z_1 according to the resistivity of the soil.....	127
Table E.2 – Expected surge overcurrents due to lightning flashes.....	129

Preview Only

Committee representation

The Electrotechnical Industry Standards Committee (ISC E) under whose authority this Malaysian Standard was adopted, comprises representatives from the following organisations:

Association of Consulting Engineers Malaysia
Department of Standards Malaysia
Federation of Malaysian Manufacturers
Independent Power Producer Association
Jabatan Kerja Raya Malaysia
Malaysian Cable Manufacturers Association
Malaysian Electrical Appliances and Distributors Association
Ministry of Domestic Trade and Consumer Affairs
Ministry of International Trade and Industry
Persatuan Pengguna-Pengguna Standard Malaysia
Pusat Tenaga Malaysia
SIRIM QAS International Sdn Bhd
Suruhanjaya Komunikasi dan Multimedia Malaysia
Suruhanjaya Tenaga
Tenaga Nasional Berhad
The Electrical and Electronics Association of Malaysia
The Institution of Engineers, Malaysia
Universiti Teknologi Malaysia

The Working Group on Lightning Protection which recommends adoption of the IEC Standard consists of representatives from the following organisations:

Association of Consulting Engineers Malaysia
Institute of Engineer Malaysia
Jabatan Kerja Raya Malaysia (Cawangan Kejuruteraan Elektrik)
Lightning Research Sdn Bhd
Markas Angkatan Tentera Malaysia
Mega Jati Consult Sdn Bhd
Pertubuhan Akitek Malaysia
SIRIM Berhad
SIRIM QAS International Sdn Bhd
Tenaga Nasional Berhad
The Electrical and Electronics Association of Malaysia
TM Research and Development
TNB Research Sdn Bhd
Universiti Teknologi Malaysia

NATIONAL FOREWORD

The adoption of the IEC Standard as a Malaysian Standard was recommended by the Technical Committee on Electromagnetic Compatibility (EMC) under the authority of the Electrotechnical Industry Standards Committee (ISC E).

This Malaysian Standard is identical with IEC 62305-1:2006, *Protection Against Lightning – Part 1: General principles*, published by the International Electrotechnical Commission (IEC). However, for the purposes of this Malaysian Standard, the following apply:

- a) in the source text, “this International Standard” should read “this Malaysian Standard”;
and
- b) the comma which is used as a decimal sign (if any), to read as a point.

MS IEC 62305 consist of the following parts, under the general title *Protection against lightning*:

- *Protection against lightning-Part 1: General principles*
- *Protection against lightning-Part 2: Risk management*
- *Protection against lightning-Part 3: Physical damage to structures and life hazard*
- *Protection against lightning-Part 4: Electrical and electronic systems within structures*

This standard cancels and replaces

- a) MS IEC 61024-1:2001, *Protection of structures against lightning Part 1: General principles*
- b) MS IEC 61024-1-1:2001, *Protection of structures against lightning Part 1: General principles Section 1: Guide A - Selection of protection levels of lightning protection systems*
- c) MS IEC 61024-1-2: 2001, *Protection of structures against lightning Part 1-2: General principles, Guide B - Design, installation, maintenance and inspection of lightning protection systems*

Compliance with a Malaysian Standard does not of itself confer immunity from legal obligations.

NOTE. IDT on the front cover indicates an identical standard i.e. a standard where the technical content, structure, and wording (or is an identical translation) of a Malaysian Standard is exactly the same as in an International Standard or is identical in technical content and structure although it may contain the minimal editorial changes specified in clause 4.2 of ISO/IEC Guide 21-1.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROTECTION AGAINST LIGHTNING –**Part 1: General principles**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-1 has been prepared by IEC technical committee 81: Lightning protection.

The IEC 62305 series (Parts 1 to 5), is produced in accordance with the New Publications Plan, approved by National Committees (81/171/RQ (2001-06-29)), which restructures and updates in a more simple and rational form the publications of the IEC 61024 series, the IEC 61312 series and the IEC 61663 series.

The text of this first edition of IEC 62305-1 is compiled from and replaces

- IEC 61024-1-1, first edition (1993).

The text of this standard is based on the following documents:

FDIS	Report on voting
81/262/FDIS	81/267/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 2.

IEC 62305 consists of the following parts, under the general title *Protection against lightning*:

- Part 1: General principles
- Part 2: Risk management
- Part 3: Physical damage to structures and life hazard
- Part 4: Electrical and electronic systems within structures
- Part 5: Services¹

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

¹ To be published