



MALAYSIAN STANDARD

MS IEC 62305-3:2007

**PROTECTION AGAINST LIGHTNING-PART 3:
PHYSICAL DAMAGE TO STRUCTURES AND
LIFE HAZARD
(FIRST REVISION)
(IEC 62305-3:2006, IDT)**

ICS: 91.120.40, 29.020

Descriptors: lightning protection, installations and contents

© Copyright 2007

DEVELOPMENT OF MALAYSIAN STANDARDS

The **Department of Standards Malaysia (STANDARDS MALAYSIA)** is the national standardisation and accreditation body.

The main function of the Department is to foster and promote standards, standardisation and accreditation as a means of advancing the national economy, promoting industrial efficiency and development, benefiting the health and safety of the public, protecting the consumers, facilitating domestic and international trade and furthering international cooperation in relation to standards and standardisation.

Malaysian Standards are developed through consensus by committees which comprise of balanced representation of producers, users, consumers and others with relevant interests, as may be appropriate to the subject in hand. To the greatest extent possible, Malaysian Standards are aligned to or are adoption of international standards. Approval of a standard as a Malaysian Standard is governed by the Standards of Malaysia Act 1996 (Act 549). Malaysian Standards are reviewed periodically. The use of Malaysian Standards is voluntary except in so far as they are made mandatory by regulatory authorities by means of regulations, local by-laws or any other similar ways.

The Department of Standards appoints **SIRIM Berhad** as the agent to develop Malaysian Standards. The Department also appoints SIRIM Berhad as the agent for distribution and sale of Malaysian Standards.

For further information on Malaysian Standards, please contact:

Department of Standards Malaysia
Level 1 & 2, Block C4, Parcel C
Federal Government Administrative Centre
62502 Putrajaya
MALAYSIA

Tel: 60 3 88858000
Fax: 60 3 88885060

<http://www.standardsmalaysia.gov.my>

E-mail: central@standardsmalaysia.gov.my

OR **SIRIM Berhad**
(Company No. 367474 - V)
1, Persiaran Dato' Menteri
P.O. Box 7035, Section 2
40911 Shah Alam
Selangor D.E.

Tel: 60 3 5544 6000
Fax: 60 3 5510 8095

<http://www.sirim.my>

CONTENTS

COMMITTEE REPRESENTATION.....	iv
NATIONAL FOREWORD.....	vi
FOREWORD.....	11
INTRODUCTION.....	15
1 Scope.....	17
2 Normative references	17
3 Terms and definitions	19
4 Lightning protection system (LPS).....	25
4.1 Class of LPS	25
4.2 Design of the LPS	27
4.3 Continuity of steelwork in reinforced concrete structures	27
5 External lightning protection system	29
5.1 General.....	29
5.2 Air-termination systems	29
5.3 Down-conductor systems.....	37
5.4 Earth-termination system.....	43
5.5 Components	47
5.6 Materials and dimensions.....	51
6 Internal lightning protection system	57
6.1 General.....	57
6.2 Lightning equipotential bonding	57
6.3 Electrical insulation of the external LPS	63
7 Maintenance and inspection of an LPS	65
7.1 Application of inspections.....	65
7.2 Order of inspections	65
7.3 Maintenance.....	65
8 Protection measures against injury to living beings due to touch and step voltages	67
8.1 Protection measures against touch voltages.....	67
8.2 Protection measures against step voltages.....	67
Annex A (normative) Positioning the air-termination system.....	69
Annex B (normative) Minimum cross-section of the entering cable screen in order to avoid dangerous sparking	81
Annex C (informative) Partitioning of the lightning current amongst down-conductors	83
Annex D (informative) Additional information for LPS in the case of structures with a risk of explosion.....	91
Annex E (informative) Guidelines for the design, construction, maintenance and inspection of lightning protection systems	103
Bibliography.....	307

Figure 1 – Loop in a down-conductor	39
Figure 2 – Minimum length l_1 of each earth electrode according to the class of LPS.....	43
Figure A.1 – Volume protected by a vertical air-termination rod	69
Figure A.2 – Volume protected by a vertical air-termination rod	71
Figure A.3 – Volume protected by a wire air-termination system	71
Figure A.4 – Volume protected by isolated wires combined in a mesh according to the protective angle method and rolling sphere method	73
Figure A.5 – Volume protected by non-isolated wires combined in a mesh according to the mesh method and the protective angle method	75
Figure A.6 – Design of an air-termination system according to the rolling sphere method	77
Figure C.1 – Values of coefficient k_c in the case of a wire air-termination system and a type B earth-termination system.....	85
Figure C.2 – Values of coefficient k_c in the case of a mesh air-termination system and type B earth-termination system.....	87
Figure C.3 – Examples of calculation of the separation distance in the case of a meshed air-termination system, an interconnecting ring of the down-conductors at each level and a type B earth-termination system	89
Figure E.1 – LPS design flow diagram	107
Figure E.2 – Values of coefficient k_c in case of a sloped roof with air-termination on the ridge and a type B earthing system	121
Figure E.3 – LPS design for a cantilevered part of a structure.....	123
Figure E.4 – Equipotential bonding in a structure with a steel reinforcement	127
Figure E.5 – Welded joints of reinforcing rods in reinforced concrete, if permitted.....	129
Figure E.6 – Example of clamps used as joints between reinforcing rods and conductors	131
Figure E.7 – Examples for connection points to the reinforcement in a reinforced concrete wall	133
Figure E.8 – Use of metallic facade as natural down-conductor system and connection of facade supports	141
Figure E.9 – Connection of the continuous strip windows to a metal façade covering.....	143
Figure E.10 – Internal down-conductors in industrial structures.....	149
Figure E.11– Installation of bonding conductors in reinforced concrete structures and flexible bonds between two reinforced concrete parts	153
Figure E.12 – Protective angle method air-termination design for different heights according to Table 2	161
Figure E.13 – Isolated external LPS using two isolated air-termination masts designed according to the protective angle air-termination design method	163
Figure E.14 – Isolated external LPS using two isolated air-termination masts, interconnected by horizontal catenary wire	165
Figure E.15 – Example of design of an air-termination of a non-isolated LPS by air-termination rods.....	167
Figure E.16 – Example of design of an air-termination of a non isolated LPS by a horizontal wire according to the protective angle air-termination design method	169
Figure E.17 – Protected volume of an air- termination rod or mast on a sloped surface.....	171

Figure E.18 – Design of an LPS air-termination according to the rolling sphere method, protective angle method, mesh method and general arrangement of air-termination elements	175
Figure E.19 – Design of an LPS air-termination conductor network on a structure with complicated shape	177
Figure E.20 – Space protected by two parallel air-termination horizontal wires or two air-termination rods ($r > h_t$)	179
Figure E.21 – Points at which lightning will strike a building	183
Figure E.22 – Example of design of non-isolated LPS air-termination according to the mesh method air-termination design	191
Figure E.23 – Some examples of details of an LPS on a structure with sloped tiled roofs	197
Figure E.24 – Construction of an LPS using natural components on the roof of the structure	201
Figure E.25 – Positioning of the external LPS on a structure made of insulating material e.g. wood or bricks with a height up to 60 m with flat roof and with roof fixtures	203
Figure E.26 – Construction of air-termination network on a roof with conductive covering where puncturing of the covering is not acceptable	205
Figure E.27 – Construction of external LPS on a structure of steel-reinforced concrete using the reinforcement of the outer walls as natural components	207
Figure E.28 – Example of an air-termination stud used on car park roofs	209
Figure E.29 – Air-termination rod used for protection of a metallic roof fixture with electric power installations which are not bonded to the air-termination system	211
Figure E.30 – Method of achieving electrical continuity on metallic parapet cladding	213
Figure E.31 – Metallic roof fixture protected against direct lightning interception, connected to air-termination system	219
Figure E.32 – Example of construction of lightning protection of a house with a TV antenna using the mast as an air-termination rod	223
Figure E.33 – Installation of lightning protection of metallic equipment on a roof against a direct lightning flash	225
Figure E.34 – Connection of natural air-termination rod to air-termination conductor	229
Figure E.35 – Construction of the bridging between the segments of the metallic façade plates	231
Figure E.36 – Installation of external LPS on a structure of isolating material with different roof levels	235
Figure E.37 – Examples of geometry of LPS conductors	237
Figure E.38 – Construction of an LPS using only two down-conductors and foundation earth electrodes	239
Figure E.39 – Examples of connection of earth termination to the LPS of structures using natural down-conductors (girders) and detail of a test joint	247
Figure E.40 – Construction of foundation earth ring for structures of different foundation design	255
Figure E.41 – Examples of two vertical electrodes in type A earthing arrangement	259
Figure E.42 – Meshed earth termination system of a plant	267

Figure E.43 – Examples of separation distance between the LPS and metal installations	279
Figure E.44 – Directions for calculations of the separation distance s for a worst case lightning interception point at a distance l from the reference point according to 6.3	281
Figure E.45 – Example of an equipotential bonding arrangement	287
Figure E.46 – Example of bonding arrangement in a structure with multiple point entries of external conductive parts using a ring electrode for interconnection of bonding bars	289
Figure E.47 – Example of bonding in the case of multiple point entries of external conductive parts and an electric power or communication line using an internal ring conductor for interconnection of the bonding bars	291
Figure E.48 – Example of bonding arrangement in a structure with multiple point entries of external conductive parts entering the structure above ground level	293
Table 1 – Relation between lightning protection levels (LPL) and class of LPS (see IEC 62305-1)	25
Table 2 – Maximum values of rolling sphere radius, mesh size and protection angle corresponding to the class of LPS	31
Table 3 – Minimum thickness of metal sheets or metal pipes in air-termination systems	35
Table 4 – Typical values of the distance between down-conductors and between ring conductors according to the class of LPS	39
Table 5 – LPS materials and conditions of use	49
Table 6 – Material, configuration and minimum cross-sectional area of air-termination conductors, air-termination rods and down-conductors	53
Table 7 – Material, configuration and minimum dimensions of earth electrodes	55
Table 8 – Minimum dimensions of conductors connecting different bonding bars or connecting bonding bars to the earth-termination system	59
Table 9 – Minimum dimensions of conductors connecting internal metal installations to the bonding bar	59
Table 10 – Isolation of external LPS – Values of coefficient k_i	63
Table 11 – Isolation of external LPS – Values of coefficient k_c	63
Table 12 – Isolation of external LPS – Values of coefficient k_m	65
Table B.1 – Cable length to be considered according to the condition of the screen	81
Table C.1 – Values of coefficient k_c	83
Table E.1 – Suggested fixing centres	193
Table E.2 – Maximum period between inspections of an LPS	297

Committee representation

The Electrotechnical Industry Standards Committee (ISC E) under whose authority this Malaysian Standard was adopted, comprises representatives from the following organisations:

Association of Consulting Engineers Malaysia
Department of Standards Malaysia
Federation of Malaysian Manufacturers
Independent Power Producer Association
Jabatan Kerja Raya Malaysia
Malaysian Cable Manufacturers Association
Malaysian Electrical Appliances and Distributors Association
Ministry of Domestic Trade and Consumer Affairs
Ministry of International Trade and Industry
Persatuan Pengguna-Pengguna Standard Malaysia
Pusat Tenaga Malaysia
SIRIM QAS International Sdn Bhd
Suruhanjaya Komunikasi dan Multimedia Malaysia
Suruhanjaya Tenaga
Tenaga Nasional Berhad
The Electrical and Electronics Association of Malaysia
The Institution of Engineers, Malaysia
Universiti Teknologi Malaysia

The Working Group on Lightning Protection which recommends adoption of the IEC Standards consists of representatives from the following organisations:

Association of Consulting Engineers Malaysia
Institute of Engineer Malaysia
Jabatan Kerja Raya Malaysia (Cawangan Kejuruteraan Elektrik)
Lightning Research Sdn Bhd
Markas Angkatan Tentera Malaysia
Mega Jati Consult Sdn Bhd
Pertubuhan Akitek Malaysia
SIRIM Berhad
SIRIM QAS International Sdn Bhd
Tenaga Nasional Berhad
The Electrical and Electronics Association of Malaysia
TM Research and Development
TNB Research Sdn Bhd
Universiti Teknologi Malaysia

NATIONAL FOREWORD

The adoption of the IEC Standard as a Malaysian Standard was recommended by the Technical Committee on Electromagnetic Compatibility (EMC) under the authority of the Electrotechnical Industry Standards Committee (ISC E).

This Malaysian Standard is identical with IEC 62305-3:2006, *Protection Against Lightning – Part 3: Physical damage to structures and life hazard*, published by the International Electrotechnical Commission (IEC). However, for the purposes of this Malaysian Standard, the following apply:

- a) in the source text, “this International Standard” should read “this Malaysian Standard”;
- b) the comma which is used as a decimal sign (if any), to read as a point;
- c) references to normative reference should be replaced by Malaysian Standard.

MS IEC 62305 consist of the following parts, under the general title *Protection against lightning*:

- *Protection against lightning Part-1: General principles*
- *Protection against lightning Part-2: Risk management*
- *Protection against lightning Part-3: Physical damage to structures and life hazard*
- *Protection against lightning Part-4: Electrical and electronic systems within structures*

This standard cancels and replaces:

- a) MS IEC 61024-1:2001, *Protection of structures against lightning Part 1: General principles*
- b) MS IEC 61024-1-1:2001, *Protection of structures against lightning Part 1: General principles Section 1: Guide A - Selection of protection levels of lightning protection systems*
- c) MS IEC 61024-1-2: 2001, *Protection of structures against lightning Part 1-2: General principles, Guide B- Design, installation, maintenance and inspection of lightning protection systems*

Compliance with a Malaysian Standard does not of itself confer immunity from legal obligations.

NOTE. IDT on the front cover indicates an identical standard i.e. a standard where the technical content, structure, and wording (or is an identical translation) of a Malaysian Standard is exactly the same as in an International Standard or is identical in technical content and structure although it may contain the minimal editorial changes specified in clause 4.2 of ISO/IEC Guide 21-1.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROTECTION AGAINST LIGHTNING –

Part 3: Physical damage to structures and life hazard

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC national committees). The object of the IEC is to promote international cooperation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes international standards, technical specifications, technical reports, publicly available specifications (PAS) and guides (hereafter referred to as "IEC publication(s)"). Their preparation is entrusted to technical committees; any IEC national committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC national committees.
- 3) IEC publications have the form of recommendations for international use and are accepted by IEC national committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC publications is accurate, the IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC national committees undertake to apply IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to the IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC national committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC publication or any other IEC publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC publication may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International standard IEC 62305-3 has been prepared by IEC technical committee 81: Lightning protection.

The IEC 62305 series (Parts 1 to 5), is produced in accordance with the new Publications' Plan, approved by National Committees (81/171/RQ (2001-06-29)), which restructures in a more simple and rational form and updates the Publications of the IEC 61024 series, the IEC 61312 series and the IEC 61663 series.

The text of this first edition of IEC 62305-3 is compiled from and replaces

- IEC 61024-1, first edition (1990).
- IEC 61024-1-2, first edition (1998).

The text of this standard is based on the following documents:

FDIS	Report on voting
81/264/FDIS	81/269/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above Table.

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 2.

IEC 62305 consists of the following parts, under the general title *Protection against lightning*:

Part 1: General principles

Part 2: Risk management

Part 3: Physical damage to structures and life hazard

Part 4: Electrical and electronic systems within structures

Part 5: Services¹

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC website "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition; or
- amended.

In the United States, based on the requirements of NFPA 780: Standard for the Installation of Lightning Protection Systems 2004 Edition and practical experience in the use of horizontal earth electrodes, the minimum length of horizontal earth electrodes is not required to be twice that required for vertical electrodes.

In France, Portugal and Spain:

- natural components cannot substitute as lightning protection components but may be used to complete/enhance the LPS;
- aluminium solid round diameters should be extended from 8 mm to 10 mm;
- stranded conductors cannot be used as down-conductors;
- diameter of solid round conductors should be extended from 16 mm to 18 mm;
- hot dip galvanized steel solid tape thickness should be extended from 2 mm to 3,5 mm.

¹ To be published