



MALAYSIAN STANDARD

MS 1910:2006

FIXED FIREFIGHTING SYSTEMS – AUTOMATIC SPRINKLER SYSTEMS – DESIGN, INSTALLATION AND MAINTENANCE

ICS: 13.220.20

Descriptors: fixed fire-fighting systems, automatic sprinkler, design, installation, maintenance

© Copyright 2006

DEPARTMENT OF STANDARDS MALAYSIA

DEVELOPMENT OF MALAYSIAN STANDARDS

The **Department of Standards Malaysia (DSM)** is the national standardisation and accreditation body.

The main function of the Department is to foster and promote standards, standardisation and accreditation as a means of advancing the national economy, promoting industrial efficiency and development, benefiting the health and safety of the public, protecting the consumers, facilitating domestic and international trade and furthering international cooperation in relation to standards and standardisation.

Malaysian Standards are developed through consensus by committees which comprise of balanced representation of producers, users, consumers and others with relevant interests, as may be appropriate to the subject in hand. To the greatest extent possible, Malaysian Standards are aligned to or are adoption of international standards. Approval of a standard as a Malaysian Standard is governed by the Standards of Malaysia Act 1996 (Act 549). Malaysian Standards are reviewed periodically. The use of Malaysian Standards is voluntary except in so far as they are made mandatory by regulatory authorities by means of regulations, local by-laws or any other similar ways.

The Department of Standards appoints **SIRIM Berhad** as the agent to develop Malaysian Standards. The Department also appoints SIRIM Berhad as the agent for distribution and sale of Malaysian Standards.

For further information on Malaysian Standards, please contact:

Department of Standards Malaysia
Level 1 & 2, Block C4, Parcel C
Federal Government Administrative Centre
62502 Putrajaya
MALAYSIA

Tel: 60 3 88858000
Fax: 60 3 8885060

<http://www.dsm.gov.my>

E-mail: central@dsm.gov.my

OR **SIRIM Berhad**
(Company No. 367474 - V)
1, Persiaran Dato' Menteri
P.O. Box 7035, Section 2
40911 Shah Alam
Selangor D.E.

Tel: 60 3 5544 6000
Fax: 60 3 5510 8095

<http://www.sirim.my>

CONTENTS

	Page
Committee representation.....	ix
Foreword.....	x
0 Introduction	1
1 Scope.....	2
2 Normative references.....	3
3 Terms and definitions.....	5
4 Extent of sprinkler protection.....	12
4.1 Buildings and areas to be protected.....	12
4.2 Storage in the open air.....	13
4.3 Fire resistant separation.....	13
4.4 Protection of concealed spaces.....	13
4.5 Height difference between the highest and lowest sprinklers.....	13
5 Classification of occupancies and fire hazards.....	14
5.1 General.....	14
5.2 Hazard classes	14
5.3 Storage.....	16
6 Hydraulic design criteria.....	19
6.1 LH, OH and HPP	19
6.2 High Hazard Storage – HHS	20
6.3 Pressure and flow requirements for per-calculated systems	22
7 Water supplies.....	25
7.1 General.....	25
7.2 Maximum water pressure	26
7.3 Housing of equipment for water supplies	27
7.4 Connections for other services	27
7.5 Test facility devices	27
7.6 Water supply test.....	28
8 Type of water supply.....	29
8.1 General.....	29
8.2 Storage tanks	29
8.3 Inexhaustible sources	33
8.4 Choice of water supply	37
8.5 Isolation of water supply.....	38

CONTENTS (*continued*)

	Page
9 Pumps	38
9.1 General.....	38
9.2 Multiple pump arrangements	39
9.3 Compartments for pumpsets	39
9.4 Maximum temperature of water supply	40
9.5 Valves and accessories	40
9.6 Suction conditions	40
9.7 Performance characteristics	45
9.8 Electrically driven pumpsets	48
9.9 Diesel engine driven pumpsets	52
10 Installation type and size	56
10.1 Wet pipe installations.....	56
10.2 Dry pipe installations	58
10.3 Pre-action installations	58
10.4 Subsidiary dry pipe extension	59
10.5 Subsidiary water spray extension	60
11 Spacing and location of sprinklers	60
11.1 General	60
11.2 Maximum area of coverage per sprinkler	61
11.3 Minimum distance between sprinklers	62
11.4 Location of sprinklers in relation to building construction	62
11.5 Intermediate sprinklers in HH occupancies	69
12 Pipe sizing and layout	75
12.1 General	75
12.2 Calculation of pressure losses in pipework	75
12.3 Pre-calculated systems	78
12.4 Fully calculated systems	96
13 Sprinkler design characteristics and uses	101
13.1 General.....	101
13.2 Sprinkler types and application	102
13.3 Flow from sprinklers	103
13.4 Sprinklers temperature ratings	103
13.5 Sprinkler thermal sensitivity	104
13.6 Sprinkler guards	104
13.7 Sprinkler water shields	104

CONTENTS (*continued*)

	Page
13.8 Sprinkler rosettes	105
13.9 Corrosion protection of sprinklers	105
14 Valves	105
14.1 Control valve set	106
14.2 Stop valves	106
14.3 Ring main valves	107
14.4 Drain valves.....	107
14.5 Test valves	108
14.6 Flushing connections.....	109
14.7 Pressure relief valves	109
14.8 Pressure gauges	110
15 Alarms and alarm devices	110
15.1 Water motor alarm and gong	110
15.2 Electrical water flow and pressure switches	111
15.3 Fire brigade and remote central station alarm connection	111
16 Pipework	112
16.1 General	112
16.2 Pipe supports	114
16.3 Pipework in concealed spaces	120
17 Signs, notices and information	121
17.1 Block plan	121
17.2 Signs and notices	121
18 Commissioning and acceptance tests and periodic inspection	124
18.1 Commissioning and acceptance tests and periodic inspection	124
18.2 Completion certificate and documents	125
19 Maintenance.....	125
19.1 General	125
19.2 User's programme of inspection and checking	126
19.3 Service and maintenance schedule	127
20 Evaluation of conformity	130
20.1 Sprinkler kit	130
20.2 Sprinkler system	131

CONTENTS (*continued*)

	Page
Tables	
1	Maximum storage heights for OH1, OH2 and OH3 (see Note 2) 15
2	Limitations and protection requirements for different storage configuration 18
3	Design criteria for LH, OH and HHP 20
4	Design criteria for HHS with roof for ceiling protection only (without in -rack intermediate sprinkler protection) 21
5	Design criteria for roof or ceiling sprinklers with in -rack (intermediate) sprinkler protection 22
6	Pressure and flow requirements for pre-calculated LH and OH systems 23
7	Pressure and flow requirements for HHP and HHS pre -calculated installations designed using Tables 32 to 35 24
8	Connections for water for other services in low rise systems 27
9	Minimum water volume for pre-calculated LH and OH systems 30
10	Minimum water volume for pre-calculated HHP and HHS systems 31
11	Suction pipe inlet clearances 32
12	Nominal diameter for feed pipes or conduits for setting and suction chambers ... 36
13	Pump pressure and flow rating 42
14	Pump priming tank capacity and pipe size 43
15	Minimum pump characteristics for LH and OH (pre -calculated systems) 46
16	Maximum number of sprinklers in wet pipe and pre-action installations 57
17	Maximum size per installation – dry and alternate installations..... 58
18	Maximum coverage and spacing for sprinklers other than sidewall 61
19	Maximum coverage and spacing for sidewall sprinklers 62
20	Location of intermediate sprinklers in type ST5 and ST6 storage 74
21	C values for various types of pipe 76
22	Equivalent length of fittings and valves 77
23	Accuracy of hydraulic calculations 77
24	Location of design points – LH 82
25	Location of design points – OH, HHP and HHS..... 82
26	Range pipe diameters for LH installations 83
27	Maximum friction loss between control valve set and any design point – LH..... 83
28	Pressure loss for design flow rates LH installations 84
29	Range pipe diameters in OH installations 85
30	Distribution pipe diameters in OH installations 85
31	Pressure loss per unit length of pipe for design flow rates in ordinary-hazard installations..... 86
32	Range pipe diameters for HH installations with pressure and flow characteristics as given in Table 7 (1 or 2) and sprinklers having a K factor of 80 88
33	Distribution pipe diameters downstream of the design point, in HH installations with pressure and flow characteristics as given in Table 7 (1) and sprinklers having a K factor of 80 88
34	Distribution pipe diameters downstream of the design point in HH installations with pressure and flow characteristics as given in Table 7 (2, 3 or 4) and sprinklers having a K factor of 80 or 115 89
35	Range pipe diameters for HH installations with pressure and flow characteristics as given in Table 7 (3 or 4) and sprinklers having a K factor of 115 90

CONTENTS (*continued*)

	Page
36 Minimum pipe diameters	101
37 Sprinkler types and K factors for various hazard classes	102
38 Sprinkler temperature rating and colour coding	103
39 Sprinkler sensitivity ratings	104
40 Minimum size of drain valves	108
41 Maximum distance between pipe supports	118
42 Design parameters for pipe support.....	119
43 Minimum dimension of flat iron rods and clips	120
44 Minimum dimension of sling rods and 'U' bolts	120
A1 Light Hazard occupancies	132
A2 Ordinary Hazard occupancies	132
A3 High Hazard Process occupancies	134
B1 Categories as a function of storage configuration	137
C1 Stored products and categories	140
G1 Protection criteria for aerosol storage	154
G2 Flammable liquids in metal drums (ST1) with a capacity > 20 L and < 208 L	157
G3 Flammable liquids in metal drums (ST4) with a capacity > 20 L and < 208 L	157
G4 Flammable liquids in metal drums (ST1, ST5, ST6) with a capacity < 20 L	157
G5 Protection of idle pallets (ST1)	158
G6 Protection of rack storage of pallets (ST4, ST5, ST6)	158
G7 Non-woven synthetic fabric: Design criteria with roof or ceiling protection only	159
J1 Type of alarm for transmission	164
K1 Orifice plate thickness according to pipe nominal bore	165
K2 Orifice plates for 50 and 65 mm medium grade pipes complying with MS 863 ...	167
K3 Orifice plates for 80, 100, 150 and 200 mm medium grade pipes complying with MS 863	168
M1 Table of number of sprinklers to be inspected	171
Figures	
1 Main elements of a sprinkler installation	1
2 Flow chart for determining the class required for storage	16
3 Storage configuration	19
4 Effective capacity of suction tanks and dimensions of suction chambers	34
5 Settling and suction chambers	35
6 Pump suction inlet taper	41
7 Pump priming arrangement for suction lift	44

CONTENTS (*continued*)

	Page
8 Pump arrangement for positive suction	45
9 Typical pump curve	47
10 Electrical supply schematic for pumps	50
11 Ceiling sprinkler spacing	61
12 Sprinkler location relative to beams	64
13 Distance of sprinkler deflector from beams	65
14 Beam and bay spacing (beams in one direction only)	66
15 Beam and bay spacing (beams in both directions)	67
16 Location of rack intermediate level sprinkler – Category I or II	71
17 Location of rack intermediate level sprinkler – Category III or IV	72
18 Location of intermediate sprinklers in type ST5 and ST6 storage	74
19 Examples of range pipe arrays	79
20 OH and HH pre-calculated installations – armpipes and risers (or drops)	80
21 Example of application of design points in an LH installation.....	84
22 Example A of application of design points in an OH installation	91
23 Example B of application of design points in an OH installation	92
24 Example of application of design points in a high hazard installation with pipe sizes from Tables 32 and 33.....	93
25 Example of application of design points in a high hazard installation with pipes sizes from Tables 32 and 34.....	94
26 Example of application of design points in a high hazard installation with pipe sizes from Tables 34 and 35.....	95
27 Determination of area covered per sprinkler	96
28 Most unfavourable areas of operation in one-sided and two-sided pipe layouts ..	98
29 Most favourable areas of operation in one-sided and two-sided pipe layouts	99
30 Most favourable and unfavourable areas of operation in gridded pipe layouts	100
31 Most favourable and unfavourable areas of operation in a looped pipe layout	100
32 Typical pipe support components	115
33 Typical method of support for extended spans exceeding the requirements of Table 41.....	118
 B1 Material factor	 136
D1 Control valve bypass arrangement for zoned building installations	146
E1 Typical layout of high rise system with pump supply	149
E2 Typical layout of high rise system with gravity tanks and booster pumps	150
F1 Duplicate alarm valve arrangement for life safety installation	152
G1 Typical sprinkler protection of garment racks	155
 Annexes	
A Classification of hazard	132

CONTENTS (*continued*)

	Page
B Methodology for categorising stored goods	134
B1 General	135
B2 Material factor (M)	135
B3 Storage configuration	137
C Alphabetic listing of stored products and categories	140
D Zoning of sprinkler installations	143
D1 General	143
D2 Zoning of installations	143
D3 Requirements for zoned installations	143
D4 Block pan	145
E Special requirements for high rise systems	147
E1 General	147
E2 Design criteria	147
E3 Water supplies	148
F Special requirements for life safety system s	151
F1 Subdivision into zones	151
F2 Wet pipe installations	151
F3 Sprinkler type and sensitivity	151
F4 Control valve set	151
F5 Water supplies.....	152
F6 Theatres	152
F7 Additional precautions for maintenance	153
G Protection of special hazards.....	154
G1 General	154
G2 Aerosols.....	154
G3 Clothes in multiple garment hanging storage	154
G4 Flammable liquid storage	156
G5 Idle pallets.....	158
G6 Spirit based liquors in wooden barrels	158
G7 Non-woven synthetic fabric	159
G8 Polypropylene or polyethylene storage bins	159
H Sprinkler systems monitoring	161
H1 General	161
H2 Functions to be monitored	161

CONTENTS (*continued*)

	Page
J Transmission of alarms	163
J1 Functions to be monitored	163
J2 Alarm levels	163
K Orifice plate design and installation	165
K1 General	165
K2 Use of Tables K2 and K3.....	166
L Precautions and procedures when a system is not fully operational	169
L1 Minimising the effects	169
L2 Planned shutdown	169
L3 Unplanned shutdown	170
L4 Action following sprinkler operation	170
M Twenty five year inspection	171
N Special technology	172

Committee representation

The Fire Safety and Prevention Industry Standards Committee (ISC M) under whose authority this Malaysian Standard was developed, comprises representatives from the following organisations:

Association of Consulting Engineers Malaysia
Construction Industry Development Board Malaysia
Department of Chemistry, Malaysia
Department of Standards Malaysia
Forest Research Institute Malaysia
Jabatan Bomba dan Penyelamat Malaysia
Jabatan Kerja Raya Malaysia
Malaysian Fire Protection Association
Master Builders Association of Malaysia
Ministry of International Trade and Industry
Persatuan Insuran Am Malaysia
Pertubuhan Akitek Malaysia
Real Estate Housing Developers' Association Malaysia
The Institution of Engineers, Malaysia
The Institution of Fire Engineers (UK) Malaysia Branch
Universiti Kebangsaan Malaysia
Universiti Putra Malaysia

The Technical Committee on Wet Fire Prevention, which supervised the development of this Malaysian Standard consists of representatives from the following organisations:

Association of Consulting Engineers Malaysia
Jabatan Bomba dan Penyelamat Malaysia
Jabatan Kerja Raya Malaysia (Cawangan Kejuruteraan Mekanikal)
Kolling Engineering Sdn Bhd
Malaysian Fire Protection Association
Persatuan Akitek Malaysia
Persatuan Insuran Am Malaysia
SIRIM Berhad (Secretariat)
SIRIM QAS International Sdn Bhd (Fire Engineering Testing Section)
SIRIM QAS International Sdn Bhd (Product Certification Section)
Steel Recon Industries Sdn Bhd
Tenaga Nasional Berhad
The Institution of Engineers, Malaysia
The Institution of Fire Engineers (UK) Malaysia Branch
Universiti Putra Malaysia

The Working Group on Sprinkler which developed this Malaysian Standard consists of representatives from the following organisations:

Kejuruteraan Bintai Kindenko Sdn Bhd
Mark Jaya - Vital Sdn Bhd
MEP Engineering Sdn Bhd
Norman Disney and Young Sdn Bhd
Pan Engineering Sdn Bhd

FOREWORD

This Malaysian Standard was developed by the Working Group on Sprinkler under the authority of the Fire Safety and Prevention Industry Standards Committee.

Compliance with a Malaysian Standard does not of itself confer immunity from legal obligations.