



MALAYSIA STANDARD

MS 61000-3-6:2010

ELECTROMAGNETIC COMPATIBILITY (EMC) - PART 3-6: LIMITS - ASSESSMENT OF EMISSION LIMITS FOR THE CONNECTION OF DISTORTING INSTALLATION TO MV, HV AND EHV POWER SYSTEMS (FIRST REVISION)

ICS: 33.100.10

Descriptors: electromagnetic compatibility, limits, assessment, emission limits, connection, distorting installations, MV, HV, EHV power systems

© Copyright 2010

DEPARTMENT OF STANDARDS MALAYSIA

DEVELOPMENT OF MALAYSIAN STANDARDS

The **Department of Standards Malaysia (STANDARDS MALAYSIA)** is the national standards and accreditation body of Malaysia.

The main function of STANDARDS MALAYSIA is to foster and promote standards, standardisation and accreditation as a means of advancing the national economy, promoting industrial efficiency and development, benefiting the health and safety of the public, protecting the consumers, facilitating domestic and international trade and furthering international cooperation in relation to standards and standardisation.

Malaysian Standards (MS) are developed through consensus by committees which comprise balanced representation of producers, users, consumers and others with relevant interests, as may be appropriate to the subject at hand. To the greatest extent possible, Malaysian Standards are aligned to or are adoption of international standards. Approval of a standard as a Malaysian Standard is governed by the Standards of Malaysia Act 1996 [Act 549]. Malaysian Standards are reviewed periodically. The use of Malaysian Standards is voluntary except in so far as they are made mandatory by regulatory authorities by means of regulations, local by-laws or any other similar ways.

STANDARDS MALAYSIA has appointed **SIRIM Berhad** as the agent to develop, distribute and sell the Malaysian Standards.

For further information on Malaysian Standards, please contact:

Department of Standards Malaysia
Ministry of Science, Technology and Innovation
Level 1 & 2, Block 2300, Century Square
Jalan Usahawan
63000 Cyberjaya
Selangor Darul Ehsan
MALAYSIA

Tel: 60 3 8318 0002
Fax: 60 3 8319 3131
<http://www.standardsmalaysia.gov.my>

E-mail: central@standardsmalaysia.gov.my

SIRIM Berhad
(Company No. 367474 - V)
1, Persiaran Dato' Menteri
Section 2
40000 Shah Alam
Selangor Darul Ehsan
MALAYSIA

Tel: 60 3 5544 6000
Fax: 60 3 5510 8095
<http://www.sirim.my>

E-mail: msonline@sirim.my

CONTENTS

	Page
Committee representation.....	iv
Foreword.....	v
1 Scope.....	1
2 Normative references.....	2
3 Terms and definitions.....	2
4 Basic EMC concepts related to harmonic distortion.....	8
5 General principles.....	15
6 General guidelines for the assessment of emission levels.....	17
7 General summation law.....	23
8 Emission limits for distorting installations connected to MV systems.....	24
9 Emission limits for distorting installations connected to HV-EHV systems.....	34
10 Interharmonics.....	38
Table 1 Compatibility levels for individual harmonic voltages in low and medium voltage networks (percent of fundamental component) reproduced from MS IEC 61000-2-2 [5] and MS IEC 61000-2-12 [6].....	9
Table 2 Indicative planning levels for harmonic voltages (in percent of the fundamental voltage) in MV, HV and EHV power systems.....	10
Table 3 Summation exponents for harmonics (indicative values).....	24
Table 4 Weighting factors W_j for different types of harmonic producing equipments.....	26
Table 5 Indicative values for some odd order harmonic current emission limits relative to the size of a customer installation.....	27

CONTENTS *(continued)*

	Page
Table A1 Feeder characteristics for the system under consideration	45
Table A2 Determination of F and S_{xl} values for the feeders.....	45
Table B1 Influence coefficients K_{hj-1} between node j and node 1	51
Table B2 Reduction factors.....	54
Table B3 Global contributions G_{hB1} at node 1	55
Table C1 Acceptable global contribution G_{hMV+LV} of the MV and LV installations to the MV harmonic voltages if the transfer coefficient from the HV-EHV system is considered to be unity	57
Figure 1 Illustration of basic voltage quality concepts with time/location statistics covering the whole system	13
Figure 2 Illustration of basic voltage quality concepts with time statistics relevant to one site within the whole system	13
Figure 3 Illustration of the emission vector U_{hi} and its contribution to the measured harmonic vector at the point of evaluation	17
Figure 4 Example of a system for sharing global contributions at MV.....	28
Figure 5 Diagram of evaluation procedure at MV.....	33
Figure 6 Determination of S_t for a simple HV or EHV system	34
Figure 7 Allocation of planning level to a substation in HV-EHV system.....	35
Figure A1 Example of an MV distribution system showing the MV transformer and feeders 1-6	43
Figure B1 HV-EHV system considered for the connection of a new distorting installation at node 1 substation	50
Figure B2 Harmonic Impedance at node 1	51
Figure B3 Harmonic Impedance at node 5 'Uranus 150 kV', when the capacitor banks at Jupiter 150 kV are switched off	52
Figure D1 Example of maximum impedance curve for a 11 kV system	58

CONTENTS *(concluded)*

	Page
Annex A Guidance for allocating planning levels and emission levels at MV.....	40
Annex B Method for sharing planning levels and allocating emission limits in meshed HV - EHV systems.....	47
Annex C Example of calculation of global MV + LV contribution.....	57
Annex D Envelope of the maximum expected impedance.....	58
Annex E List of symbols and subscripts.....	60
Bibliography	64