



MALAYSIAN STANDARD

MS 1395:2011,
AMD. 1:2015

**Pillar fire hydrants - Specification
(First revision)**

AMENDMENT 1

ICS: 13.220.10

Descriptors: pillar fire hydrant, specification, design, manufacture, material, test method, marking, evaluation of conformity

© Copyright 2015

DEPARTMENT OF STANDARDS MALAYSIA

AMENDMENT OF MALAYSIAN STANDARD

MALAYSIAN STANDARD

MS 1395:2011

PILLAR FIRE HYDRANTS - SPECIFICATION
(FIRST REVISION)

(1) **Figure 3, Page 7**

To amend key for Figure 3 to be read as follows:

“Key

No.	Description	Standard reference	Material
1	Nuts	BS 4190	Mild steel
2	Hand wheel	EN 1561	Cast iron
3	Spindle	EN 12165	Gunmetal
4	Instantaneous knob	EN 1982	Gunmetal
5	Adaptor	EN 1982	Gunmetal
6	Body	MS 1828	Ductile Iron
7	Spindle bottom flange	EN 1982	Gunmetal
8	Rubber pad	MS 672	Rubber
9	Screwed end inlet	EN 1982	Gunmetal

”

(2) **Clause 4.17.2, Page 17**

To delete paragraph 3.

(3) **Clause 4.18, Page 17**

To amend the clause to be read as follows:

“The outer surface of the body shall be coated with an approved fire hydrant reflective paint of red colour for public hydrants and yellow colour for private hydrants except where the hydrant is pressurised in which case the colour shall be in red.”