



MALAYSIAN STANDARD

MS 2112-3:2009,
AMD. 1:2015

Electric cable and wire - Polyvinyl chloride (PVC) insulated cables of rated voltages up to and including 450/750 V - Part 3: Non-sheathed cables for fixed wiring

AMENDMENT 1

ICS: 29.060

Descriptors: PVC, electric cable, non-sheathed cable, fixed wire

© Copyright 2015

DEPARTMENT OF STANDARDS MALAYSIA

AMENDMENT OF MALAYSIAN STANDARD

MALAYSIAN STANDARD

MS 2112-3:2009

ELECTRIC CABLE AND WIRE - POLYVINYL CHLORIDE (PVC) INSULATED CABLES OF RATED VOLTAGES UP TO AND INCLUDING 450/750 V - PART 3: NON-SHEATHED CABLES FOR FIXED WIRING

(1) In each of the table below:

Table 6, Page 9
Table 8, Page 11
Table 10, Page 13
Table 12, Page 15
Table 14, Page 17
Table 16, Page 19

For Ref. no. "1.2", under column "Test", change the whole sentence to:

"Voltage tests at 2 000 V"

E.g: Table 6, Page 9

Table 6. Tests for type MS IV 03

Ref. no.	Test	Category of test	Test method	
			Standard	Subclause
1	Electric tests			
1.1	Resistance of conductors	T, S	MS 2112-2	5.1
1.2	Voltage tests at 2 000 V	T, S	MS 2112-2	5.2
1.3	Insulation resistance at 70 °C	T	MS 2112-2	5.4
...