



MALAYSIAN STANDARD

**MS 30: PART 8:1995
(CONFIRMED:2011)**

METHODS OF TESTING AGGREGATES: PART 8: METHODS FOR DETERMINATION OF AGGREGATE CRUSHING VALUE (ACV) (FIRST REVISION)

ICS: 91.100.30

Descriptors: testing aggregates, aggregate, crushing value, ACV

© Copyright 2011

DEPARTMENT OF STANDARDS MALAYSIA

DEVELOPMENT OF MALAYSIAN STANDARDS

The **Department of Standards Malaysia (STANDARDS MALAYSIA)** is the national standards and accreditation body of Malaysia.

The main function of STANDARDS MALAYSIA is to foster and promote standards, standardisation and accreditation as a means of advancing the national economy, promoting industrial efficiency and development, benefiting the health and safety of the public, protecting the consumers, facilitating domestic and international trade and furthering international cooperation in relation to standards and standardisation.

Malaysian Standards (MS) are developed through consensus by committees which comprise balanced representation of producers, users, consumers and others with relevant interests, as may be appropriate to the subject at hand. To the greatest extent possible, Malaysian Standards are aligned to or are adoption of international standards. Approval of a standard as a Malaysian Standard is governed by the Standards of Malaysia Act 1996 [Act 549]. Malaysian Standards are reviewed periodically. The use of Malaysian Standards is voluntary except in so far as they are made mandatory by regulatory authorities by means of regulations, local by-laws or any other similar ways.

STANDARDS MALAYSIA has appointed **SIRIM Berhad** as the agent to develop, distribute and sell the Malaysian Standards.

For further information on Malaysian Standards, please contact:

Department of Standards Malaysia
Ministry of Science, Technology and Innovation
Level 1 & 2, Block 2300, Century Square
Jalan Usahawan
63000 Cyberjaya
Selangor Darul Ehsan
MALAYSIA

Tel: 60 3 8318 0002
Fax: 60 3 8319 3131
<http://www.standardsmalaysia.gov.my>

E-mail: central@standardsmalaysia.gov.my

OR **SIRIM Berhad**
(Company No. 367474 - V)
1, Persiaran Dato' Menteri
Section 2, P.O.Box 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA

Tel: 60 3 5544 6000
Fax: 60 3 5510 8095
<http://www.sirim.my>

E-mail: msonline@sirim.my

This Malaysian Standard, which had been approved by the Building and Civil Engineering Industry Standards Committee and endorsed by the Board of the Standards and Industrial Research Institute of Malaysia (SIRIM) was published under the authority of the SIRIM Board in December, 1995.

SIRIM wishes to draw attention to the fact that this Malaysian Standard does not purport to include all the necessary provisions of a contract.

The Malaysian Standards are subject to periodical review to keep abreast of progress in the industries concerned. Suggestions for improvements will be recorded and in due course brought to the notice of the Committees charged with the revision of the standards to which they refer.

The following references relate to the work on this standard:

Committee reference: SIRIM 491/2/17

Draft for comment: D174 (ISC D)R

Amendments issued since publication

Amd. No.	Date of issue	Text affected

CONTENTS

	Page
Committee representation	(iii)
Foreword	(iv)
1 Scope	1
2 Definitions	1
3 Principle	1
4 Sampling	1
5 Apparatus	2
6 Preparation of test portions and specimens	4
7 Procedure	5
8 Calculations and expression of results.....	6
9 Test report	6
Tables	
1 Principle dimensions of cylinder and plunger apparatus.....	4
2 Guide to minimum mass of test portions required to obtain a suitable mass of material to determine the aggregate crushing value	5
3 Particulars of test sieves for testing other size fractions of aggregates	8
Figure 1 Outline form of cylinder and plunger apparatus for the aggregate crushing value	3
Appendices	
A Recommended method for determining the aggregate crushing value of other size fractions	7
B Publications referred to	10

Committee representation

The Building and Civil Engineering Industry Standards Committee under whose supervision this Malaysian Standard was prepared, comprises representatives from the following Government Ministries, trade, commerce and manufacturer associations and scientific and professional bodies.

The Institution of Engineers Malaysia

Malaysian Institute of Architects

Master Builders' Association

Ministry of Housing and Local Government (Housing Department)

University of Technology Malaysia

Chartered Institute of Building (Malaysia)

Jabatan Kerja Raya Malaysia

The Working Group on Mineral Aggregates which prepared this Malaysian Standard consist of representatives from the following member organizations:

Encik Munning Jamaludin (Chairman)

The Institution of Engineers Malaysia (IEM)

Prof. Madya Ir. Hj. Mohd Hashim Daud/
Dr. Sabarudin Mohd

Universiti Sains Malaysia

Dr. Abdul Ghani Rafek

Universiti Kebangsaan Malaysia

Puan Norlainah Ab. Ghani

Jabatan Kerja Raya Malaysia

Encik Abd. Majid Sahat

Jabatan Penyiasatan Kajibumi Malaysia

Encik S. Subramaniam/Encik Aslan Osman

Institute of Quarrying Malaysian Branch

Encik Pradeep Leon

National Ready-Mixed Concrete Association of Malaysia

Encik Huang Wen Pin/Encik Arjunaidi Jamaludin

Cement and Concrete Association

Co-opted members:

Encik Tan Boon Kong

Geological Society of Malaysia

Encik Pook Fong Fee

Masters Builders Association of Malaysia

Puan Raja Nor Siha Raja Abd. Hanan

Standards and Industrial Research Institute of Malaysia

Cik Nor Fauziah Sulaiman/

Encik Mohd Azam Md. Yunus (Secretary)

Standards and Industrial Research Institute of Malaysia

FOREWORD

This Part of MS 30 has been prepared by the Working Group on Mineral Aggregate under the Building and Civil Engineering Industry Standards Committee. This standard is a revision of MS 30 : 1971, which is withdrawn.

This Part of Malaysian Standard was based on BS 812 : Part 110 : Methods for determination of aggregate crushing value (ACV).

It is intended that other Malaysian Standards should call up MS 30 test method as the basis of compliance. Nevertheless, it is not intended that all aggregates should be subjected regularly to all the listed tests. Specifications in other standards should call up only relevant tests.

Some of the tests in other Parts of MS 30 are of limited application and advice on the use of simpler tests is given, for example, when they can be used for a preliminary sorting of aggregates to see whether more extensive testing is justified.

Reference should be made to MS 30 : Part 2 for general guidance on testing aggregates, precision of test methods and variance arising from sampling errors.

Compliance with a Malaysian Standard does not of itself confer immunity from legal obligations.